

Certificate of Assessment

NK6258A

No 1460

"Copyright CSIRO 2010 ©"
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by the CSIRO Division of Materials Science and Engineering in accordance with Australian Standard 3959:2009 Construction of Buildings in bushfire-prone areas Appendix F, on behalf of:

Cyndan Chemical Solutions
1/7 Jubilee Ave
WARRIEWOOD NSW
AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FNK 10003.

SAMPLE IDENTIFICATION: Cyndan – Fire Retardant Liquid NF

DESCRIPTION OF SAMPLE: The sponsor described the tested specimen as two heavy coats of clear Cyndan Fire Retardant Liquid NF applied to Radiata Pine natural timber.

Nominal total thickness: 38 mm
Nominal mass: 18.5 kg/m²
Colour: clear coating over natural timber (light brown)

TEST RESULT:


Maximum Heat Release Rate 67.1 kW/m²
Average Heat Release Rate: 18.7 kW/m²

The specimen satisfies the requirement for bushfire-resisting timber specified in AS 3959:2009 Construction of Buildings in bushfire-prone area Appendix F.

The specimen has not been subjected to the weathering procedure of ASTM D 2898 Method B as specified by Appendix F F2(b) of AS 3959. At the discretion of the regulatory authority this material may be approved for use in situations where it is protected from the weather as referenced in Appendix F F2(b) of AS 3959.

Testing Officer: Heherson Alarde Date of Test: 23 August 2010

Issued on the 25th day of November 2010 without alterations or additions.



Garry E Collins
Manager, Fire Testing and Assessments



CSIRO Materials Science and Engineering
14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555